



St. Jude's Church

Assessment of Energy Savings Opportunities



GEP Environmental Ltd

Unit 5, Basepoint Business Centre,
1 Winnall Valley Road,
Winchester,
SO23 0LD
<http://www.gepenv.co.uk/>

Tel: 01962 600 205

Regional Offices:

Winchester, Edinburgh, Bedford,
Caerphilly, Anglesey, Hereford

St. Jude's Church

Kent Rd, Southsea
Portsmouth
Southsea
PO5 3EL
<http://www.sjs.church/>

Tel: 02392777000

Report Date: 20/10/2021

Version: 1.0



ENERGY



ENVIRONMENT



TRAINING

Contents

| | | |
|-----|-----------------------------------------------------------|----|
| 1 | Executive Summary..... | 4 |
| 2 | Project Details | 6 |
| 2.1 | Site Description | 6 |
| 3 | Energy Audit Methodology | 7 |
| 4 | Analysis of Current Energy Consumption | 7 |
| 5 | Action Plan | 8 |
| 6 | Detailed Recommendations..... | 9 |
| 7 | About GEP Environmental | 18 |
| 8 | About “EMphasis3 CO ₂ Reductions” Project..... | 19 |
| | Appendix 1 – Savings Calculations | 20 |

Disclaimer

This report has been prepared by GEP Environmental Ltd (GEP) solely for use of St. Jude's Church (summarily referred to as 'the Client') to whom it is addressed and should not be relied upon by any person or entity other than the Client without the prior written permission of GEP and the Client. This report is a feasibility study and does not represent a detailed system design.

In producing this report, GEP has relied upon information provided by third parties. Neither GEP nor their directors, employees or affiliated companies give any representation or warranty, express or implied, as to the accuracy, completeness or fairness of the contents of the report, nor accept any responsibility of liability for any loss, whether direct, indirect or consequential, arising from reliance on it.

Any use of this report by any third party for whatever purpose is solely the responsibility of that party who should use such due diligence to verify the report's contents and consult its own advisers as may be appropriate.

GEP does not give investment advice and nothing in this report constitutes or should be taken as a recommendation to enter into, or the giving of any advice in relation to, any investment. GEP and associates take no responsibility for decisions made or actions taken based upon findings of this study or the contents of this report.



This service is provided as part of the "EMphasis3 CO₂ Reductions" project which is partially funded by the 'European Regional Development Fund'.



1 Executive Summary

Opportunities for reducing energy use have been investigated at St. Jude's Church as part of a wider Building Energy Audit program through the EMphasis3 project. The following table summarises the opportunities identified during the site energy audit.


| Project Name | Utility Saved | Annual Consumption saving (kWh) | Annual Total £ saving ¹ | Annual tCO ₂ e saving | Capital Expenditure £ | Simple Payback (years) |
|-------------------------------------|---------------|---------------------------------|------------------------------------|----------------------------------|-----------------------|------------------------|
| Secondary Glazing | Natural Gas | 16,713 | 418 | 3.1 | 15,244 | 36.5 |
| Draught proofing staff entrance | Natural Gas | 3,154 | 117 | 0.6 | 275 | 2.4 |
| De-stratification fans installation | Natural Gas | 15,513 | 331 | 2.6 | 2,738 | 8.3 |
| Installation ASHP | Natural Gas | 56,226 | -1,220 | 7.9 | 107,680 | -88.3 |
| LED Upgrade | Electricity | 2,154 | 283 | 0.6 | 6,934 | 24.5 |
| Solar PV system | Electricity | 17,299 | 1,983 | 4.8 | 23,256 | 11.7 |
| Total ('Core' projects only) | | 111,059 | 1,912 | 19.6 | 156,127 | 81.7 |


Note that the total Capital Expenditure may be reduced through an application to The EMphasis3 project which looks to part-fund SME energy efficiency projects through its grant scheme, up to an intervention rate of 36%.

The table below summarises the estimated CO₂e emissions before and after the implementation of the above projects:

| | |
|---------------------------------------------|------|
| Estimated Annual tCO ₂ e Savings | 19.6 |
| Estimated Future Annual tCO ₂ e | 20.2 |

Simple payback and Lifetime tonnes CO₂e savings for each project are represented in the following graphs:





2 Project Details

| | |
|-------------------------|----------------------------------------------------------------|
| Consultant Name: | Shamir Robinson |
| Email address: | Shamirr@GEPEnv.co.uk |
| Site Address: | Kent Rd, Southsea, Portsmouth, Southsea PO5 3EL |
| Site Visit Date: | 8 th September 2021 |

2.1 Site Description

The St. Jude's Church is an 1851 category II Listed Building, internally divided on the vestry, chapel north & south, west face of nave, and internal balcony to aisles. The church walls are mainly Flint and rock-faced stone with stone dressings. The ceiling is a Welsh slate high roof with north and south faces. The walls are very thick, and able to retain heat very well however the large church hall space requires a considerable heat input to raise temperatures to an acceptable level. This is not helped by the ornate, single glazed windows which will be contributing to the heat losses, however secondary glazing would be a suitable intervention, which would minimise these losses and improve the building envelope. The pitched roof of the church has a south-westerly facing roof which would be ideal for a solar PV array should the necessary planning permissions be granted, and the roof be deemed able to support one.

In a typical week the church is used on Thursday, Friday, and Sunday. The church also hosts shorter services with coffee/tea after. Additionally, St. Jude's Church offer a meeting room and an activities space for Young Adults which is utilised twice on Sundays. On Fridays, the church prepares and serves dinner for the elderly in the north hall. The users of the site and the occupancy times vary regularly, and users will also have differing needs and requirements from the space.

On the boilers plant room, pipework is fully insulated. Four Ferroli Econcept 50 A - 45kW gas fired wall hung boilers provide heat to a set of single line traditional radiators, water pipe on the middle of the Nave, and two hot water fans. There are additional electric heaters on some of the meeting rooms and second floor office.

On the Office, reception, north hall, and garden meeting room an air conditioning unit is installed with an external condenser being ground-mounted within the back garden area. It appears to be well maintained and without outward issue; pipework is insulated, air paths are not blocked, and finned surfaces appear clean. The Mitsubishi Electric Central air conditioning unit can provide an estimated 63.0kW Cooling or 69kW Heating and have a stated maximum Coefficient of Performance (COP) of 4.2; up to around 420% efficient (max). The internal wall cassettes are controlled by digital wall mounted controllers.

Internal lighting at the site is a mixture of T5 fluorescent lamps, compact fluorescent lamps (CFL), and halogen recessed luminaires. Our engineers undertook a summary survey of all the floors, and it is estimated that between 10% - 20% of the site's lighting has been upgraded to energy efficient LED fittings.

For the recommendations in this report the following factors have been used:

| | |
|-----------------------------------|---------------------------------|
| Electricity Cost # | 13.20 p/kWh |
| Electricity Carbon Factor* | 0.27730 kgCO ₂ e/kWh |
| Gas Cost # | 3.70 p/kWh |
| Natural Gas Carbon Factor* | 0.18385 kgCO ₂ e/kWh |

*Based on 2019 DBEIS carbon factors.

Based on latest available bill.

For the avoidance of doubt, energy prices include CCL where appropriate but exclude delivery charges, VAT and other fixed elements.


3 Energy Audit Methodology

Energy consumption data has been sourced for the 12-month period from April 2019 to March 2020. The Gas consumption data is sourced from the client data logs. Electricity consumption data was based upon monthly energy data provided by the client.

4 Analysis of Current Energy Consumption

The energy consumption at St. Jude’s Church was for the 12-month period between April 2019 and March 2020 and is summarised below:

| Month | Electricity (kWh) | Natural Gas (kWh) | Total Energy (kWh) |
|--------------|-------------------|-------------------|--------------------|
| Apr-19 | 4,709 | 21,615 | 26,324 |
| May-19 | 1,546 | 26,880 | 28,426 |
| Jun-19 | 4,041 | 22,004 | 26,045 |
| Jul-19 | 4,420 | 17,963 | 22,383 |
| Aug-19 | 4,213 | 7,228 | 11,441 |
| Sep-19 | 1,899 | 559 | 2,458 |
| Oct-19 | 4,535 | 337 | 4,872 |
| Nov-19 | 4,162 | 392 | 4,554 |
| Dec-19 | 4,520 | 564 | 5,084 |
| Jan-20 | 5,786 | 7,133 | 12,919 |
| Feb-20 | 5,249 | 13,782 | 19,031 |
| Mar-20 | 4,496 | 21,992 | 26,488 |
| Total | 49,576 | 140,449 | 190,025 |



Please note that the cost above is based on the basic cost per kWh including CCL where appropriate and doesn't include VAT or fixed elements such as standing charges so the values in this report may be lower than the invoiced energy values.

5 Action Plan

The following table provides a summary of the measures identified. A detailed analysis of each measure is shown in section 6.

| Project Name | Utility Saved | Annual Consumption saving (kWh) | Annual Total £ saving ¹ | Annual tCO ₂ e saving | Capital Expenditure £ | Simple Payback (years) |
|-------------------------------------|---------------|---------------------------------|------------------------------------|----------------------------------|-----------------------|------------------------|
| Secondary Glazing | Natural Gas | 16,713 | 418 | 3.1 | 15,244 | 36.5 |
| Draught proofing staff entrance | Natural Gas | 3,154 | 117 | 0.6 | 275 | 2.4 |
| De-stratification fans installation | Natural Gas | 15,513 | 331 | 2.6 | 2,738 | 8.3 |
| Installation ASHP | Natural Gas | 56,226 | -1,220 | 7.9 | 107,680 | -88.3 |
| LED Upgrade | Electricity | 2,154 | 283 | 0.6 | 6,934 | 24.5 |
| Solar PV system | Electricity | 17,299 | 1,983 | 4.8 | 23,256 | 11.7 |
| Total ('Core' projects only) | | 111,059 | 1,912 | 19.6 | 156,127 | 81.7 |

¹The total cost saving includes all cost savings (energy, renewable income) and is adjusted for any additional annual costs (e.g. maintenance, staff costs).

Note that the total Capital Expenditure may be reduced through an application to The EMphasis3 project which looks to part-fund SME energy efficiency projects through its grant scheme, up to an intervention rate of 36%.

6 Detailed Recommendations

Recommendation 1:

| | | |
|-----------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|
| Description | Secondary Glazing on Largest Windows | |
| Technology Type | Insulation - Building fabric: Secondary glazing | |
| Project Description | <p>The site, especially the Nave and the Chancel, has large single-glass windows which will be contributing significantly to heat losses from that space.</p> <p>Installing secondary glazing internally will reduce the electricity consumed to heat the inhabited spaces and portable electric heaters will be less likely to be required during colder periods. The secondary glazing is more likely to be an acceptable intervention for a listed building as it will keep the character of the ornate stained-glass windows.</p> | |
| Costs | Capital Costs: | £15,244 |
| | Additional Annual Operating Costs: | £0 |
| Annual Savings | Energy (kWh) | 16,713 |
| | Running Costs: | £418 |
| | Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 3.1 |
| | Other Cost savings: | £0 |
| | Potential RHI / FiT Income: | £0 |
| | Total £ Savings: | £418 |
| | Simple Payback (years) | 36.48 |
| Lifetime Emissions savings | Lifetime GHG emission savings (tCO2e) | 86.0 |

Calculations and assumptions

Refer to Appendix 1 of this report for savings calculations.

Pricing is aligned to domestic windows; commercial or safety aspects that are required will increase costs.

The cost of redecoration following the installation of the windows has been excluded.

Approximate dimensions were taken for window location to allow for estimation and financial modelling. Quoting suppliers should take their own measurements to ensure units are manufactured at the correct size for the install work.

Smaller windows should be inspected and included within an upgrade project as required.

It is assumed that any necessary planning permission for this measure will be approved.

Risks and Issues:

The installation would require the area immediately surrounding each window to be emptied.

Working at height from ladders/platforms will be invasive and put staff and site visitors at risk - it is likely that when work is in progress then it will affect the usability of the affected spaces.

Full RAMS will be required when quotations are submitted.


Implementation of Energy Saving Opportunities:

Survey the priority, larger windows to determine the optimal design for each replacement window.

Invite suppliers to quote for supply and fit with accompanying RAMS.

Schedule the installation with the agreement of the site users.

Monitor for and make any changes to the heating system as the need for heat should change.

| Recommendation 2: | | | | | | | | | | | | | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|-------|------------------------------------|------|--------------------------------------------------------|-----|---------------------|----|-----------------------------|----|------------------|------|------------------------|-----|
| Description | Draught proofing staff entrance | | | | | | | | | | | | | | |
| Technology Type | Insulation - Draught proofing | | | | | | | | | | | | | | |
| Project Description | <p>The staff entrance located on the back access has an internal door as shown in the picture below than can be improve with new seals to reduce the cold air infiltration in winter months.</p>  <p>Implementing newly install door sealing internally will reduce the gas consumed to heat the inhabited spaces and portable electric heaters will be less likely to be required during colder periods. Additionally, by working on the inner's doors the external protected building fabric is not required to be changed.</p> | | | | | | | | | | | | | | |
| Costs | <table> <tr> <td>Capital Costs:</td> <td>£700</td> </tr> <tr> <td>Additional Annual Operating Costs:</td> <td>£0</td> </tr> </table> | Capital Costs: | £700 | Additional Annual Operating Costs: | £0 | | | | | | | | | | |
| Capital Costs: | £700 | | | | | | | | | | | | | | |
| Additional Annual Operating Costs: | £0 | | | | | | | | | | | | | | |
| Annual Savings | <table> <tr> <td>Energy (kWh)</td> <td>3,154</td> </tr> <tr> <td>Running Costs:</td> <td>£117</td> </tr> <tr> <td>Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent)</td> <td>0.6</td> </tr> <tr> <td>Other Cost savings:</td> <td>£0</td> </tr> <tr> <td>Potential RHI / FiT Income:</td> <td>£0</td> </tr> <tr> <td>Total £ Savings:</td> <td>£117</td> </tr> <tr> <td>Simple Payback (years)</td> <td>6.0</td> </tr> </table> | Energy (kWh) | 3,154 | Running Costs: | £117 | Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 0.6 | Other Cost savings: | £0 | Potential RHI / FiT Income: | £0 | Total £ Savings: | £117 | Simple Payback (years) | 6.0 |
| Energy (kWh) | 3,154 | | | | | | | | | | | | | | |
| Running Costs: | £117 | | | | | | | | | | | | | | |
| Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 0.6 | | | | | | | | | | | | | | |
| Other Cost savings: | £0 | | | | | | | | | | | | | | |
| Potential RHI / FiT Income: | £0 | | | | | | | | | | | | | | |
| Total £ Savings: | £117 | | | | | | | | | | | | | | |
| Simple Payback (years) | 6.0 | | | | | | | | | | | | | | |
| Lifetime Emissions savings | <table> <tr> <td>Lifetime GHG emission savings (tCO2e)</td> <td>17.0</td> </tr> </table> | Lifetime GHG emission savings (tCO2e) | 17.0 | | | | | | | | | | | | |
| Lifetime GHG emission savings (tCO2e) | 17.0 | | | | | | | | | | | | | | |
| <p>Calculations and assumptions</p> <p>Refer to Appendix 1 of this report for savings calculations.</p> <p>Pricing is aligned to domestic doors; commercial or safety aspects that are required will increase costs.</p> <p>The cost of redecoration following the installation of the windows has been excluded.</p> <p>Approximate dimensions were taken for doors to allow for estimation and financial modelling. Quoting suppliers should take their own measurements to ensure the correct size for the install work.</p> | | | | | | | | | | | | | | | |
| <p>Risks and Issues:</p> <p>Working at height from ladders/platforms will be invasive and put staff and site visitors at risk - it is likely that when work is in progress then it will affect the usability of the affected spaces.</p> <p>Full RAMS will be required when quotations are submitted.</p> | | | | | | | | | | | | | | | |
| <p>Implementation of Energy Saving Opportunities:</p> <p>Invite suppliers to quote for supply and fit with accompanying RAMS.</p> <p>Schedule the installation with the agreement of the site users.</p> <p>Monitor for and make any changes to the heating system as the need for heat should change.</p> | | | | | | | | | | | | | | | |

Recommendation 3:

| | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| Description | De-stratification fans installation | |
| Technology Type | Ventilation - Fans: High efficiency | |
| Project Description | <p>A church is a perfect candidate for de-stratification fans. For St. Jude’s church, the main high roof is approximately 25 meters high, When the heating is running, heat rises and accumulates at the ceiling of the building, increasing the temperature and rate of heat transfer at the roof.</p> <p>De-stratification not only saves energy and increases comfort, but it can also speed up the conditioning of the space during a morning warm-up cycle before service. In this case, the rising warm air is being captured and delivered to floor level, providing an immediate increase in comfort. Without fans, the building would heat from the “top-down” as the heated air rises and collects in the ceiling.</p> <p>De-stratification fans are specifically designed to save costs and increase comfort. The fans continuously and gently mix the air, balancing temperatures (destratification) from ceiling to floor and wall to wall which helps the heating system maintain the desired temperature.</p> | |
| Costs | Capital Costs: | £2,738 |
| | Additional Annual Operating Costs: | £0 |
| Annual Savings | Energy (kWh) | 15,513 |
| | Running Costs: | £331 |
| | Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 2.6 |
| | Other Cost savings: | £0 |
| | Potential RHI / FiT Income: | £0 |
| | Total £ Savings: | £331 |
| | Simple Payback (years) | 8.28 |
| Lifetime Emissions savings | Lifetime GHG emission savings (tCO2e) | 37.2 |
| <p>Calculations and assumptions</p> <p>Refer to Appendix 1 of this report for savings calculations.</p> <p>Pricing is aligned to estimated cost of the fans without inclusion of additional engineering work for supporting structure.</p> <p>A 11% reduction in gas consumption has been modelled.</p> <p>The cost of redecoration following the installation fans and any additional structure has been excluded.</p> <p>High velocity fans were selected to allow installation on the high part of the 25-meter-high ceiling.</p> | | |
| <p>Risks and Issues:</p> <p>Working at height from ladders/platforms will be invasive and put staff and site visitors at risk - it is likely that when work is in progress then it will affect the usability of the Church spaces.</p> <p>Full RAMS will be required when quotations are submitted.</p> | | |
| <p>Implementation of Energy Saving Opportunities:</p> <p>Survey the roof structure to determine the optimal design for each placement of the fans.</p> <p>Invite suppliers to quote for supply and fit with accompanying RAMS.</p> <p>Schedule the installation with the agreement of the site manager.</p> <p>Monitor for and make any changes to the heating system as the need for heat will reduce.</p> | | |

| Recommendation 4: | | | | | | | | | | | | | | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|----------|------------------------------------|-------|--------------------------------------------------------|-----|---------------------|----|-----------------------------|----|------------------|---------|------------------------|--------|
| Description | Install a hybrid High Temperature Air Source Heat Pump | | | | | | | | | | | | | | |
| Technology Type | Heating - Heat Pump (Air source) | | | | | | | | | | | | | | |
| Project Description | <p>The site can take advantage of renewable Air-Source Heating to reduce carbon emissions. Such systems produce up-to 2.8 units of heat for each unit of electricity consumed.</p> <p>A two-stage High-Temperature Air Source Heat Pump (ASHP) will significantly reduce the consumption of gas at the site and has been modelled using a seasonal COP of up to 280%. An air to water heat pump will capture renewable heat from within the ambient air from external thermal collectors in the back garden. This raises the temperature of water in the intermediate thermal store to 35C and the second stage water-to-water heat pump will raise the temperature in the final thermal store to up to 70C. The existing heating distribution system and heat emitters will therefore be able to be retained.</p> <p>The existing gas LTWH boilers are retained to meet the peak load during colder temperature periods. The system will incorporate automatic controls to manage the boiler capacity as required based on a combination of thermal storage temperature and detected system demand. The system controls will also optimise such that reasonably high Heat Pump Coefficient of Performance (COP) values are maintained.</p> <p>This project would allow the site to rationalise the two heating systems in the Family Centre to just one system with the ASHP providing the baseload and an existing Gas Boiler assisting during peak demand periods. Additional reduction on the use of high peak gas boiler demand can be expected if the ASHP is used in conjunction with the de-stratification fans and the Infra-red radiant heaters. There are adequate internal and external spaces for the equipment and Solar PV Arrays are already in place to provide zero carbon electricity to power the ASHP system.</p> | | | | | | | | | | | | | | |
| Costs | <table> <tr> <td>Capital Costs:</td> <td>£107,680</td> </tr> <tr> <td>Additional Annual Operating Costs:</td> <td>£864</td> </tr> </table> | Capital Costs: | £107,680 | Additional Annual Operating Costs: | £864 | | | | | | | | | | |
| Capital Costs: | £107,680 | | | | | | | | | | | | | | |
| Additional Annual Operating Costs: | £864 | | | | | | | | | | | | | | |
| Annual Savings | <table> <tr> <td>Energy (kWh)</td> <td>56,226</td> </tr> <tr> <td>Running Costs:</td> <td>-£356</td> </tr> <tr> <td>Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent)</td> <td>7.9</td> </tr> <tr> <td>Other Cost savings:</td> <td>£0</td> </tr> <tr> <td>Potential RHI / FiT Income:</td> <td>£0</td> </tr> <tr> <td>Total £ Savings:</td> <td>-£1,220</td> </tr> <tr> <td>Simple Payback (years)</td> <td>-88.28</td> </tr> </table> | Energy (kWh) | 56,226 | Running Costs: | -£356 | Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 7.9 | Other Cost savings: | £0 | Potential RHI / FiT Income: | £0 | Total £ Savings: | -£1,220 | Simple Payback (years) | -88.28 |
| Energy (kWh) | 56,226 | | | | | | | | | | | | | | |
| Running Costs: | -£356 | | | | | | | | | | | | | | |
| Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 7.9 | | | | | | | | | | | | | | |
| Other Cost savings: | £0 | | | | | | | | | | | | | | |
| Potential RHI / FiT Income: | £0 | | | | | | | | | | | | | | |
| Total £ Savings: | -£1,220 | | | | | | | | | | | | | | |
| Simple Payback (years) | -88.28 | | | | | | | | | | | | | | |
| Lifetime Emissions Savings | <table> <tr> <td>Lifetime GHG emission savings (tCO2e)</td> <td>85.9</td> </tr> </table> | Lifetime GHG emission savings (tCO2e) | 85.9 | | | | | | | | | | | | |
| Lifetime GHG emission savings (tCO2e) | 85.9 | | | | | | | | | | | | | | |
| Calculations and assumptions | | | | | | | | | | | | | | | |
| <p>Refer to Appendix 1 of this report for savings calculations.</p> <p>The driver for this project is the Carbon Saving rather than pure financial saving.</p> <p>The model has 80% of the total annual heat being provided by the ASHP systems; detailed scoping and sizing will more closely determine what is possible and the costs entailed.</p> <p>It is assumed that existing radiators will be retained, and a High Temperature Heat Pump System be installed. The existing Gas-Fired Boilers within the boiler room are proposed to be retained and their on-going good health has been assumed.</p> | | | | | | | | | | | | | | | |

Financial calculations have assumed that all electricity used by the ASHP has been sourced from the National Grid rather than the solar PV arrays.
Service costs are assumed to be £810 per system per annum.

Risks and Issues:

The sizing of the ASHP systems is critical if correct operating regimes are to be achieved. A more granular analysis of the site's heating profile should be undertaken as a feed into both the physical and financial modelling of the ASHP systems.

A full survey of all heating systems is recommended. Combining the separate existing systems within the Family Centre should be given adequate focus; this will determine the actual capital cost which may vary significantly from the estimated cost within this report.

The site is considered secure and the external elements of the ASHPs are not seen to be at risk from vandalism.

Obtain contractor work schedule including at least a generic RAMS which includes methods for internal and external work.

Implementation of Energy Saving Opportunities:

Capture heat demand data for the site at an hourly or half-hourly resolution.

Build a heat profile for the site and extend this to 12 months.

Model ASHP performance against the heat profile to determine the optimal install specification.

Conduct a procurement exercise based upon the developed ASHP System Specification and bill of materials.

Select the most suitable quotation and schedule the installation.

| Recommendation 5: | | | | | | | | | | | | | | | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|--------|------------------------------------|------|--------------------------------------------------------|-----|---------------------|----|-----------------------------|----|------------------|------|------------------------|-------|
| Description | LED Upgrade | | | | | | | | | | | | | | |
| Technology Type | LED Lighting – T5 and T8 to LED including new fitting | | | | | | | | | | | | | | |
| Project Description | <p>The centre has many different styles of luminaires and has seen upgrade to LED lamps in some situations. CFL lamps and LED panel luminaires are already in use within some areas. This project focuses on the remaining T5 lamps in the offices, Reception, Garden meeting room, Vestre, North Hall and Meeting rooms.</p> <p>The T5 lamps can be upgraded to LED to reduce the consumption of electricity. Within the Office setting it may be possible to rationalise the number of luminaires – this has not been determined during GEPs building energy efficiency survey. By installing PIR sensors and daylight sensors to control when the luminaires nearest the windows are required this will deliver optimal lighting conditions in the spaces.</p> | | | | | | | | | | | | | | |
| Costs | <table> <tr> <td>Capital Costs:</td> <td>£6,934</td> </tr> <tr> <td>Additional Annual Operating Costs:</td> <td>£0</td> </tr> </table> | Capital Costs: | £6,934 | Additional Annual Operating Costs: | £0 | | | | | | | | | | |
| Capital Costs: | £6,934 | | | | | | | | | | | | | | |
| Additional Annual Operating Costs: | £0 | | | | | | | | | | | | | | |
| Annual Savings | <table> <tr> <td>Energy (kWh)</td> <td>2,1154</td> </tr> <tr> <td>Running Costs:</td> <td>£283</td> </tr> <tr> <td>Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent)</td> <td>0.6</td> </tr> <tr> <td>Other Cost savings:</td> <td>£0</td> </tr> <tr> <td>Potential RHI / FiT Income:</td> <td>£0</td> </tr> <tr> <td>Total £ Savings:</td> <td>£283</td> </tr> <tr> <td>Simple Payback (years)</td> <td>24.48</td> </tr> </table> | Energy (kWh) | 2,1154 | Running Costs: | £283 | Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 0.6 | Other Cost savings: | £0 | Potential RHI / FiT Income: | £0 | Total £ Savings: | £283 | Simple Payback (years) | 24.48 |
| Energy (kWh) | 2,1154 | | | | | | | | | | | | | | |
| Running Costs: | £283 | | | | | | | | | | | | | | |
| Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 0.6 | | | | | | | | | | | | | | |
| Other Cost savings: | £0 | | | | | | | | | | | | | | |
| Potential RHI / FiT Income: | £0 | | | | | | | | | | | | | | |
| Total £ Savings: | £283 | | | | | | | | | | | | | | |
| Simple Payback (years) | 24.48 | | | | | | | | | | | | | | |
| Lifetime Emissions Savings | <table> <tr> <td>Lifetime GHG emission savings (tCO2e)</td> <td>14.9</td> </tr> </table> | Lifetime GHG emission savings (tCO2e) | 14.9 | | | | | | | | | | | | |
| Lifetime GHG emission savings (tCO2e) | 14.9 | | | | | | | | | | | | | | |
| <p>Calculations and assumptions</p> <p>Refer to Appendix 1 of this report for savings calculations.</p> <p>The main lamp types have been grouped for estimation of replacement costs including automation of control, but suitability not fully discussed with the Site Manager.</p> <p>Luminaires as retrofitting LED lamps into bi-directional may require more specific LED lamps.</p> <p>The operational hours in each location were assumed; settings such as the Meeting/Function Room are known to be less frequently used and the payback period here is longer, so it has been excluded from the LED upgrade project.</p> <p>Burn hours are based upon 5hr per day, 4 days per week for 50 weeks per annum.</p> <p>Electrician rate of £60 per hour with a fitting rate of 1 luminaire per hour.</p> <p>The cost of redecoration has been excluded.</p> | | | | | | | | | | | | | | | |
| <p>Risks and Issues:</p> <p>For the project to succeed the current requirements of each space must be fully defined before determining suitable replacement lamps and luminaires.</p> <p>The replacement works may have to be carried out outside of the service hours of the site to protect building's users and staff. No account has been made for any additional costs that result from this.</p> <p>A survey of the existing wiring of lighting should be undertaken to ensure suitability prior to committing to the upgrade. No costs have been included for remedial electrical works should the wiring be found to require upgrade.</p> | | | | | | | | | | | | | | | |

Implementation of Energy Saving Opportunities:

Re-audit the existing lighting within the spaces identified for upgrade at the point of commencing a procurement process to ensure that all recent changes or upgrades etc have been logged prior to developing a scope of works.

Provide a scope of works alongside a general electrical engineering, control & luminance requirement specification (inc. any emergency lighting requirements) and commence a supply and install procurement process. GEP can assist in verification of the proposals received.

Obtain contractor proposals including control capability and RAMS.

Select the most suitable quotation and schedule the installation.

| Recommendation 6: | | | | | | | | | | | | | | | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|---------|------------------------------------|--------|--------------------------------------------------------|-----|---------------------|----|-----------------------------|-----|------------------|--------|------------------------|-------|
| Description | Install Solar PV Array | | | | | | | | | | | | | | |
| Technology Type | Renewable Energy - Solar PV | | | | | | | | | | | | | | |
| Project Description | <p>Installing a Solar PV Array on the roof of the building will allow the site to self-generate a portion of the electricity it consumes. The array modelled here has been sized to maximise the use of the south facing roof available on top of the south Gallery. Possible excess generation that would be exported to the national grid has also been considered. By not oversizing a PV array the initial costs will be optimised and purely the site's own demand will be provided for.</p> <p>A 19.38 kW Solar PV Array has been modelled and presented here. It is anticipated to generate 19,221kWh (from modelling) of electricity annually which equates to 31% of the church's annual consumption.</p> <p>The PV Array has been costed at £1,200 per kWp installed along with an O&M cost of £20/kWp. There may be scope to install a larger array at the site subject to structural roof survey.</p> <p>The newly introduced Smart Export Guarantee (SEG) will typically pay up-to 5p/kWh of generation which is exported to the national grid. There are a number of electricity suppliers who will enter into a contract to pay for the exported generation. The site may benefit from this on weekend days and days when no production is taking place.</p> | | | | | | | | | | | | | | |
| Costs | <table> <tr> <td>Capital Costs:</td> <td>£23,256</td> </tr> <tr> <td>Additional Annual Operating Costs:</td> <td>£388</td> </tr> </table> | Capital Costs: | £23,256 | Additional Annual Operating Costs: | £388 | | | | | | | | | | |
| Capital Costs: | £23,256 | | | | | | | | | | | | | | |
| Additional Annual Operating Costs: | £388 | | | | | | | | | | | | | | |
| Annual Savings | <table> <tr> <td>Energy (kWh)</td> <td>17,299</td> </tr> <tr> <td>Running Costs:</td> <td>£2,275</td> </tr> <tr> <td>Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent)</td> <td>4.8</td> </tr> <tr> <td>Other Cost savings:</td> <td>£0</td> </tr> <tr> <td>Potential RHI / FiT Income:</td> <td>£96</td> </tr> <tr> <td>Total £ Savings:</td> <td>£1,983</td> </tr> <tr> <td>Simple Payback (years)</td> <td>11.73</td> </tr> </table> | Energy (kWh) | 17,299 | Running Costs: | £2,275 | Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 4.8 | Other Cost savings: | £0 | Potential RHI / FiT Income: | £96 | Total £ Savings: | £1,983 | Simple Payback (years) | 11.73 |
| Energy (kWh) | 17,299 | | | | | | | | | | | | | | |
| Running Costs: | £2,275 | | | | | | | | | | | | | | |
| Greenhouse Gas (GHG) Emissions (tonnes CO2 equivalent) | 4.8 | | | | | | | | | | | | | | |
| Other Cost savings: | £0 | | | | | | | | | | | | | | |
| Potential RHI / FiT Income: | £96 | | | | | | | | | | | | | | |
| Total £ Savings: | £1,983 | | | | | | | | | | | | | | |
| Simple Payback (years) | 11.73 | | | | | | | | | | | | | | |
| Lifetime Emissions savings | <table> <tr> <td>Lifetime GHG emission savings (tCO2e)</td> <td>107.9</td> </tr> </table> | Lifetime GHG emission savings (tCO2e) | 107.9 | | | | | | | | | | | | |
| Lifetime GHG emission savings (tCO2e) | 107.9 | | | | | | | | | | | | | | |
| <p>Calculations and assumptions</p> <p>Refer to Appendix 1 of this report for savings calculations.</p> <p>The site has been modelled with a low Unit Price for Electricity (13.20p/kWh).</p> <p>No account has been made for higher unit costs during peak demand periods.</p> <p>Assumed that 90% of the electricity generated will be used on site, with the extra 10% being exported to the grid.</p> <p>Shading has been applied within the model – it is anticipated that arrays positioned closer to the tower will have the effect of shading on morning hours.</p> <p>Edge protection may be required for working at heights during install and periodic maintenance of the array. This may require planning permission although less intrusive secure wire systems are available should planning be an issue. Costs for an Edge Protection system have been excluded.</p> <p>It is assumed that there is the possibility to obtain authorisation from the council to install the photovoltaic panels on a visible roof of a listed building.</p> | | | | | | | | | | | | | | | |

Risks and Issues:

The sizing of the PV array is critical, and a more granular analysis of the site's energy profile should be undertaken as a feed into both the physical and financial modelling of the PV array.

A structural survey of the roof is recommended.

There may be a minor risk for the building and the potential requirement for mitigation measures including roof CCTV, anti-theft paints and worst case, anti-theft security around the array itself.

Inverters must be located in easily accessible areas that are not surrounded by flammable materials.

SolarEdge systems should be specified for the array whereby an earth fault will create an insulation fault reaction that is designed to lead to system shutdown. In this eventuality, not only is the inverter disconnected, but the power optimisers are designed to shut down and enter safety mode, reducing the string current to zero Amps.

Solar PV technology is well understood and modelling using real climatic data eliminates over or under estimation of system yields.

DNO consent may be required via submission of a G99 application if the system is a single-phase design of > 17kWp or a three-phase design of > 50kWp. Consent should be acquired before procuring the system. The DNO will carry out a network study (which it may charge you for) to ensure that the local grid network can take the extra power that your solar PV system will generate. If the local grid network needs extra work before it can accept your connection, this will have to be done at your own cost.

Obtain contractor work schedule including at least a generic RAMS which includes methods for internal and external working at height.

An Edge Protection system will be required to protect workers during installation and future O&M of the Solar Array; costs associated with this have been excluded.

Implementation of Energy Saving Opportunities:

Capture electrical and heat demand data for the site at Half-Hourly resolution.

Build an electrical profile for the site and extend this to 12 months.

Model arrays and equipment against the electrical profile to determine the optimal install specification.

GEP have developed PV specifications and bill of materials for similar sized projects throughout the UK and can develop such a specification including general engineering / M&E specifications in liaison with St. Jude's Church.

Conduct a procurement exercise based upon the developed PV specification and bill of materials.

Select the most suitable quotation and schedule the installation.

7 About GEP Environmental

Our Service Offering

GEP Environmental are leading providers of environmental and energy consultancy services to clients across the United Kingdom & Ireland. We support organisations to identify, implement and maintain environmental, energy and training solutions. Our highly qualified project teams consist of environmental consultants, energy engineers and trainers with expertise in carbon management, ISO management systems, sustainable resource and waste management, energy efficiency, building surveying, low carbon building design and renewables.

Further information is available from <http://www.gepenv.co.uk/>

Our Technical Capabilities

We pride ourselves on our ability to deliver practical long-term solutions that create financial benefits and add value to our clients' services, buildings, portfolios and credentials. Our technical capabilities include:

- ISO 14001 Environmental Management Systems, ISO 50001 Energy Management Systems and ISO 9001 Quality Management Systems;
- Legislation & Compliance Services (Energy, Waste, Pollution Control, Buildings Operations, Permitting);
- Sustainability Reporting (FTSE4Good, CDP, GRESB, EPRA, CRC, ESOS, SECR);
- Waste Management Auditing and Compliance Support;
- IEMA Certified Training (IEMA Approved and IEMA Certified Training Courses);
- Feasibility Studies and Energy Efficiency Auditing;
- Implementation support including design, specification, evaluation and project management;
- Measurement and Verification (M&V);
- Programme Management and Technical Advisory.

Our teams maintain membership with professional bodies including the Institute of Environmental Management and Assessment (IEMA), the Institute of Environmental Sciences (IES) and the Energy Institute (EI).

Our Certifications

We are committed to service excellence and developing first class client relationships. Our quality and environmental standards are underpinned by our ISO 9001:2015 (QMS) and ISO 14001:2015 (EMS) certification.



8 About “EMphasis3 CO₂ Reductions” Project

EMphasis3 CO₂ Reductions (known as EMphasis3) is a European Regional Development Fund (ERDF) funded SME support project, led by the University of Portsmouth and delivered through the cleantech cluster Greentech South (GTS) based at the University of Portsmouth, in partnership with the University of Winchester.

EMphasis3 CO₂ Reductions aims to support the shift towards a low carbon economy in the Enterprise M3 (EM3) region and beyond, by promoting energy efficiency and renewable energy use in SMEs and promoting research and innovation in, and adoption of, low carbon technologies.

EMphasis3 will enable SMEs to reduce CO₂ emissions by using four funded interventions:

- Energy Efficiency Audits
- Energy Efficiency Grants (EEG) to part-fund energy saving/efficiency equipment or implement the recommendations of the audit
- Innovation Audits
- Innovation (Research and Development) Grants to enable SMEs to take low carbon innovations closer to commercialisation

The EMphasis3 project will run from 1st July 2019 - 30th June 2022 and will part-fund SME energy efficiency projects through its grant scheme, up to an intervention rate of 36%.



Appendix 1 – Savings Calculations

Recommendation 1:

| Description | Technology Type | Capital Cost | Additional Annual Operating Costs | Other Costs (e.g. staff) | Utility Saved | Consumption Saving | Units | £ Saving | tCO2e Saving | Other Cost Savings | Potential RHI/ FIT Income | |
|----------------------------|------------------------------------------------|--------------|-----------------------------------|--------------------------|---------------------|-------------------------------------------------------------------------------|----------------------------------|-----------|--------------|--------------------|---------------------------|--|
| Secondary Glazing | Insulation - Building fabric: Double glazing v | 15,244 | | | Natural Gas | 16,713.4310 | kWh | 417.84 | 3.073 | | | |
| Temperature Differential | | 12 ° C | | | | | | | | | | |
| Heating system efficiency | | 75% | | | | | | | | | | |
| Type | | Height (m) | Width (m) | Number of windows | Area m ² | Old U-Value (W/m ² k) | New U-Value (W/m ² k) | Saving kW | | | | |
| 1 | Nave 2nd level- Single Glazed | 1 | 0.5 | 12 | 6.00 | 5 | 2.2 | 0.202 | | | | |
| 2 | Nave 3rd level- Single Glazed | 1 | 0.75 | 2 | 1.50 | 5 | 2.2 | 0.050 | | | | |
| 3 | Nave 1st level- Single Glazed | 1 | 0.5 | 4 | 2.00 | 5 | 2.2 | 0.067 | | | | |
| 4 | Nave Ground level- Single Glazed | 0.75 | 0.5 | 2 | 0.75 | 5 | 2.2 | 0.025 | | | | |
| 5 | Vestres- single Glazed | 0.25 | 1.25 | 1 | 0.31 | 5 | 2.2 | 0.011 | | | | |
| 6 | Jouth halls - Single glazed | 1.75 | 1 | 2 | 3.50 | 5 | 2.2 | 0.118 | | | | |
| 7 | Meeting room south - Single Glazed | 1 | 0.75 | 2 | 1.50 | 5 | 2.2 | 0.050 | | | | |
| 8 | Office top Floor skylitghs | 0.75 | 0.5 | 2 | 0.75 | 5 | 2.2 | 0.025 | | | | |
| 9 | Small windows (Toilet and hallways) | 0.25 | 0.25 | 10 | 0.63 | 5 | 2.2 | 0.021 | | | | |
| | | | Total | 37 | 16.94 | | | 0.569 | | | | |
| Calculations: | | | | Revised heat loss | | | | | | | | |
| Heating consumption | 119,382 kWh | | | Roof | 22% | Note: The building currently have double glazing in almos 25% of all windows. | | | | | | |
| Heat Loss Proportion (%) | 25% | | | Windows | 25% | Single glazed | 100% | | | | | |
| Heat Losses | 29,845 kWh | | | Skylights | 0% | | | | | | | |
| Heat Loss Saving | 16,713 kWh | | | Walls | 9% | | | | | | | |
| Window Area | 17 m ² | | | Floor | 9% | | | | | | | |
| Unit Cost | 900 £/m ² | | | Vent & Inf | 35% | | | | | | | |
| Glazing Cost | £15,243.75 | | | Total | 100% | | | | | | | |
| Additional Cost (Optional) | £0.00 | | | | | | | | | | | |
| TOTAL Cost | £15,243.75 | | | | | | | | | | | |
| Energy Reduction | 14.0% | | | | | | | | | | | |
| Split Gas | | | | | | | | | | | | |
| Heating & cooling | 85% | | | | | | | | | | | |
| Lightning | 0% | | | | | | | | | | | |
| Other | 15% | | | | | | | | | | | |
| TOTAL | 100% | | | | | | | | | | | |

Recommendation 2:

| Description | Technology Type | Capital Cost | Additional Annual Operating Costs | Other Costs (e.g. staff) | Utility Saved | Consumption Saving | Units | £ Saving | tCO2e Saving | Other Cost Savings | Potential RHI/ FIT Income | Simple Payback |
|---------------------------------|-------------------------------|--------------|-----------------------------------|--------------------------|---------------------|----------------------------------|----------------------------------|-----------|--------------|--------------------|---------------------------|----------------|
| Draught proofing staff entrance | Insulation - Draught proofing | 700 | | | Natural Gas | 3,154 | kWh | 116.65 | 0.58 | | | 6.00 |
| Temperature Differential | | 12 °C | | | | | | | | | | |
| Heating system efficiency | | 80% | | | | | | | | | | |
| Type | | Height (m) | Width (m) | Number of Doors | Area m ² | Old U-Value (W/m ² K) | New U-Value (W/m ² K) | Saving kW | Cost | Hours | Saving kWh | |
| 1 | Staff access Door | 2.25 | 2.5 | 1 | 5.63 | 5 | 2.6 | 0.162 | 500 | 8,760 | 1,774 | |
| 2 | Internal Doors | 2 | 0.75 | 5 | 7.50 | 4 | 2.6 | 0.126 | 200 | 8,760 | 1,380 | |
| | Total | | | 6 | 13.13 | | | 0.288 | 700 | | 3,154 | |

Recommendation 3:

| Description | Technology Type | Capital Cost | Additional Annual Operating Costs | Other Costs (e.g. staff) | Utility Saved | Consumption Saving | Units | £ Saving | tCO2e Saving | Other Cost Savings | Potential RHI/ FIT Income | Simple Payback |
|---------------------------------------|-------------------------------------|--------------|-----------------------------------|--------------------------|---------------|---------------------|--------------------|--------------|--------------|--------------------|---------------------------|----------------|
| De-stratification fans installation | Ventilation - Fans: High efficiency | £2,738 | | | Natural Gas | 15,513 | kWh | £331 | 2.61 | | | 8.28 |
| Description | Technology Type | Utility | Units | Base Consumption | % reduction | Reduced Consumption | Consumption saving | Cost Savings | tCO2e saving | Capital Cost | | |
| 4xDe-stratification fans installation | Ventilation - Fans: High efficiency | Natural Gas | kWh | 120,582 | 15% | 102,495 | 18,087 | £669 | 3.325 | £2,400 | | |
| additional electricity consumption | Ventilation - Fans: High efficiency | Electricity | kWh | -2,574 | 100% | 0 | -2,574 | -£338 | -0.714 | £338 | | |
| | | | | | | 0 | 0 | | | | | |
| Total | | | | | | | 15,513 | £331 | 2.612 | £2,738 | | |

STANDARD SERIES TECHNICAL SPECIFICATIONS



Recommendation 4:

| Description | Technology Type | Capital Cost | Additional Annual Operating Costs | Other Costs (e.g. staff) | Utility Saved | Consumption Saving | Units | £ Saving | tCO2e Saving | Other Cost Savings | Potential RHI/ FIT Income | Simple Payback |
|-------------------|-----------------------------------------|--------------|-----------------------------------|--------------------------|---------------|--------------------|-------|----------|--------------|--------------------|---------------------------|----------------|
| Installation ASHP | Heating - Fossil Fuel to Heat Pump (Air | £72,320 | £810 | | Natural Gas | 52,712 | kWh | -£334 | 7.43 | | £0 | -63.24 |

| | | |
|-----------------------------|---------|--------|
| Existing boiler efficiency | 88% | |
| Heat Requirement | 90,195 | kWh |
| Present Fuel Usage | 102,495 | kWh |
| % replaced by new ASHP | 75% | |
| New ASHP Capacity | 135 | kW |
| Heat generated by new ASHP | 67,646 | kWh |
| New ASHP efficiency | 280% | |
| New electricity requirement | 24,159 | kWh |
| New electricity cost | £3,177 | |
| New electricity emissions | 6,699 | kgCO2e |
| Residual boiler fuel usage | 25,624 | kWh |
| Residual boiler fuel cost | £948 | |
| Residual boiler emissions | 4,711 | kgCO2e |
| Present fuel cost | £3,791 | |
| Present fuel emissions | 18,844 | kgCO2e |
| Emissions Saving | 7,433 | kgCO2e |
| RHI annual income | £0 | |

Recommendation 5:

| Description | Technology Type | Capital Cost | Additional Annual Operating Costs | Other Costs (e.g. staff) | Utility Saved | Consumption Saving | Units | £ Saving | tCO2e Saving | Other Cost Savings | Potential RHI/ FIT Income | Simple Payback |
|-------------|-----------------------------------------------------|--------------|-----------------------------------|--------------------------|---------------|--------------------|-------|----------|--------------|--------------------|---------------------------|----------------|
| LED Upgrade | LED Lighting - Halogen to LED including new fitting | £6,934 | | | Electricity | 2,154 | kWh | 283.26 | 0.60 | | | 24.48 |

| Zone | Existing | | | | Replacement | | | | Capital Cost | Saving | | | Payback (yrs) |
|---------------------------|------------------------|-----|-------|--------------------|--------------------------------------|-----|-------|--------------------|--------------|--------|-----|--------------------|---------------|
| | Lamp Type | No. | Hours | Controls Reduction | Lamp Type | No. | Hours | Controls Reduction | | kWh | £ | kg CO ₂ | |
| Offices | T5 (HE) 4' double | 4 | 2,496 | | New 4' LED T8 double fitting (2x20W) | 4 | 2,496 | | £533 | 200 | £28 | 55 | 19.2 |
| Front Office | T5 (HE) 4' double | 4 | 2,496 | | New 4' LED T8 double fitting (2x20W) | 4 | 2,496 | | £533 | 200 | £28 | 55 | 19.2 |
| reception | recessed CFL (1 x 26W) | 8 | 2,496 | | 1 x retrofit 2/4-pin 8W LED lamps | 8 | 2,496 | | £462 | 379 | £53 | 105 | 8.8 |
| Garden Meeting Room | recessed CFL (1 x 26W) | 9 | 2,496 | | 1 x retrofit 2/4-pin 8W LED lamps | 9 | 2,496 | | £520 | 427 | £59 | 118 | 8.8 |
| Tower | recessed CFL (1 x 18W) | 2 | 2,496 | | 1 x retrofit 2/4-pin 8W LED lamps | 2 | 2,496 | | £115 | 55 | £8 | 15 | 15.1 |
| Chancel Below | Led Spotlitgh 40w | 4 | 2,496 | | | 4 | 2,496 | | | | | | |
| Nave | Led Spotlitgh 20w | 20 | 2,496 | | | 20 | 2,496 | | | | | | |
| Vestre | T5 (HE) 4' double | 3 | 2,496 | | New 4' LED T8 double fitting (2x20W) | 3 | 2,496 | | £400 | 150 | £21 | 42 | 19.2 |
| Staff access area | T5 (HE) 4' double | 2 | 2,496 | | New 4' LED T8 double fitting (2x20W) | 2 | 2,496 | | £267 | 100 | £14 | 28 | 19.2 |
| North Hall | T5 (HE) 4' single | 5 | 624 | | New 4' LED T8 single fitting (20W) | 5 | 624 | | £439 | 31 | £4 | 9 | 101.3 |
| Kitchen | T5 (HE) 4' double | 5 | 624 | | New 4' LED T8 double fitting (2x20W) | 5 | 624 | | £666 | 62 | £9 | 17 | 76.8 |
| Toilets GF | Standard CFL 18W | 7 | 416 | | LED bulb style 16.5W | 7 | 416 | | £397 | 4 | £1 | 1 | 654.1 |
| South Gallery | 2D CFL 28W | 12 | 1,248 | | New LED 2D fitting 11W | 12 | 1,248 | | £770 | 300 | £42 | 83 | 18.5 |
| West Gallery | 2D CFL 28W | 8 | 1,248 | | New LED 2D fitting 11W | 8 | 1,248 | | £514 | 200 | £28 | 55 | 18.5 |
| Meeting Room south | T5 (HE) 4' single | 6 | 312 | | New 4' LED T8 single fitting (20W) | 6 | 312 | | £527 | 19 | £3 | 5 | 202.5 |
| Meeting Room North (jouth | T5 (HE) 4' single | 9 | 312 | | New 4' LED T8 single fitting (20W) | 9 | 312 | | £790 | 28 | £4 | 8 | 202.5 |

Recommendation 6:

| Description | Technology Type | Capital Cost | Additional Annual Operating Costs | Other Costs (e.g. staff) | Utility Saved | Consumption Saving | Units | £ Saving | tCO2e Saving | Other Cost Savings | Potential RHI/ FIT Income | Simple Payback |
|----------------------------------|---------------------------------|--------------|-----------------------------------|--------------------------|---------------|-----------------------|-------|----------|--------------|--------------------|---------------------------|----------------|
| Solar PV system | Renewable Energy - Solar | £23,256 | £388 | | Electricity | 17,299 | kWh | £2,275 | 4.80 | | £96 | 11.73 |
| Key parameters in model: | | | Outputs from model: | | | | | | | | | |
| Orientation | South | | Annual generation kWh | 19,221 | | System PV % Coverage: | | 31% | | | | |
| Inclination (tilt) | 25 | | Annual self supply kWh | 17,299 | | System PV(kWh/kW): | | 991.82 | | | | |
| Solar Irradiance file used | PVGIS-SARAH | | Annual export kWh | 1,922 | | | | | | | | |
| System size (kW peak) | 19.38 | | System efficiency | 75.74% | | | | | | | | |
| Annual operating cost per kWp | £20 | | Potential FIT payments | £96 | | | | | | | | |
| Import electricity price (£/kWh) | 0.1315 | | Displaced electricity | £2,275 | | | | | | | | |
| FIT income tariff (£/kWh) | 0 | | Financial position after year 1 | £1,983 | | | | | | | | |
| FIT export tariff (£/kWh) | 0.05 | | Capital cost | £23,256 | | | | | | | | |
| % of generation exported | 10% | | Simple Payback (yrs) | 11.73 | | | | | | | | |
| Calculation Data: | | Units | | | | | | | | | | |
| Panel Rating: | 380 | Watts | | | | | | | | | | |
| Area Panel | 1.82 | M2 | | | | | | | | | | |
| Cost per kWp (Pitch roof) | 1200 | £/kW | | | | | | | | | | |
| Annual Operating Cost | 20 | £/kW | | | | | | | | | | |
| System Irradiance file Used | PVGIS-SARAH | n/a | | | | | | | | | | |
| Panel Model: | LONGI SOLAR LR6-72HPH-380M 380W | | | | | | | | | | | |
| colour | | | | | | | | | | | | |
| Areas | JC-001 | JC-002 | | | | | | | | | | |
| Type of roof | Pitched | Pitched | | | | | | | | | | |
| PV Orientation(°) | 189 | 189 | | | | | | | | | | |
| Angle(°) | 25 | 25 | | | | | | | | | | |
| Area (m2) | 68.89 | 44.05 | | | | | | | | | | |
| system size (kW peak) | 11.78 | 7.6 | | | | | | | | | | |
| Annual Generation | 12,196.03 | 7,025.36 | | | | | | | | | | |
| System Efficiency | 80.0% | 71% | | | | | | | | | | |



GEP Environmental Ltd

Unit 5, Basepoint Business Centre, 1 Winnall Valley Road, Winchester, SO23 0LD

64a Queen Street, Edinburgh, EH2 4NA

Suite A, 18 Grove Place, Bedford, MK40 3JJ

Smart Zone 5, Tredomen Innovation & Technology Centre, Tredomen Park, Ystrad Mynach, Hengeod, Caerphilly, CF82 7FN

M-Sparc, Parc Gwyddoniaeth Menai, Gaerwen, Anglesey, LL60 6AG

11 Market Square, Bromyard, Herefordshire, HR7 4BP

T: 01962 600205

<http://www.gepenv.co.uk/>